



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0051 – CPR – 0267

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

POWER SUPPLY EQUIPMENT FOR FIRE DETECTION AND FIRE ALARM SYSTEMS

Trademark: **VENITEM**
Model: **TUL375 EN**

Other information: **see ANNEX**

Produced by:
VENITEM S.r.l
Via del Lavoro 10 – 30030 Salzano (VE), Italy

In the manufacturing plant(s):
PI.H000EK

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-4:1997 + A1:2002 + A2:2006

under system **1** are applied and that **the product fulfills all the prescribed requirements set out above.**

This certificate cancels and replaces the certificate having the same number and issued on 2016-07-28 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

ING. V. BAGGIO
CPR TECHNICAL DIRECTOR

Milan, 2020-01-27

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011.
IMQ S.p.A. Identification Number is: 0051.

ANNEX

0051–CPR–0267

Configuration

It is contained in a metallic enclosure with grade IP30. Internally it is fitted with the following main parts:

- No. 1 Power supply board type AL1/EN Rev. 0;
- No. 1 LED board type TCA/4;
- No. 1 Mains transformer trademark TECTOR type 3250-04/28;
- No. 2 allocable batteries 12 V – 17 Ah.

Output power supply distribution:

- 3 A current for external devices;
- 2 A current for battery recharge.